



Hackensack Meridian School of Medicine

Hackensack Meridian School of Medicine
123 Metro Blvd.
Buildings 123 and 123A
Nutley, NJ 07110

IHSC Fire Drill Report

Date: April 7th, 2023

Time: 12:00 PM

Building: 123 and 123A

Floor: All Floors

Alarm Initiation: Main fire panel placed on test and then the entire building alarm was initiated from the panel.

Full Building Evacuation: The full building was evacuated at approximately 12:00 PM. After initiation of the alarm, the strobes began followed by the audible alerts. Students, staff, and visitors then proceeded out of the building in an orderly fashion. The full evacuation of the building took approximately three minutes and 20 seconds. Evacuation was monitored by facilities and public safety personnel throughout the building.

Evacuation After Action Items:

- Evacuation time was appropriate.
- Drill was unannounced.
- Students and staff did evacuate from the proper stairwells and muster in the proper locations within the parking lot. This demonstrates that training during orientations and refreshers is penetrating the population appropriately.

Sean Fitzgerald
Manager of EHS and Biosafety

Date